


.56 (14) DIA. HOLES
(4) TYP. EACH END
TYP. EACH TERMINAL

SWITCH STYLE NO.	RATINGS					POST INSUL NEMA TR*	DIMENSIONS IN INCHES MILLIMETERS SHOWN IN ()						WEIGHT/POLE (INCL. INSUL.)		
	NOM kV	MAX kV	kV BIL	AMPS	MOM kA		"A"	"B"	"C"	"D"	"E"	"R"	"T"	LBS.	kG
C04B007G01	115	123	550	1200	61	286	58.22	45	50.50	37	19.25	36.38	.25	759	(344)
C04B007G02				1600	70		(6)						764	(347)	
C04B007G03				2000	100		(13)						805	(365)	
C04B007G04	138	145	650	1200	61	288	67.22	54	52	41	24.50	41.25	.25	879	(399)
C04B007G05				1600	70		(6)						884	(401)	
C04B007G06				2000	100		(13)						925	(420)	
C04B007G07	161	170	750	1200	61	291	75.22	62	46	41	29	41.25	.25	1272	(577)
C04B007G08				1600	70		(6)						1279	(580)	
C04B007G09				2000	100		(13)						1324	(601)	

NOTES:

1. LEFT HAND SWING SHOWN
RIGHT HAND SWING (OPP. HAND).
2. COPPER TERMINAL PADS.
3. CUSTOMER TO SUPPLY "X" & "Y" DIMENSIONS.
4. ALL DIMENSIONS ARE IN INCHES.
5. DIMENSIONS IN () ARE IN MM.
6. WEIGHTS IN () ARE IN KG.

ENGINEERING REF DWG. C04B003 & C04B010

REVISION	A: REVISE BASE COMPONENTS AND "C" DIMENSIONS. MD 2/18/04.			B: UPDATE MAX kV. LAB 9/22/04.			C: ADDED "HORIZ & VERT. MOUNTED" TO TITLE BLOCK. REMOVED "INVERT. INSUL. FOR UNDERMOUNTING". NOTE ADDED TO REFERENCE TO REVISE TO REFERENCE. RC, March 17, 2005.			D: UPDATED WEIGHTS. FWC 11/25/2008		
REV D	 Cleaveland/Price, Inc. 1400 Route 993 ; Trafford, PA, 15085									SCALE: PROPORTIONAL		
CODE A	DRAWN: PMK	CHECKED: GH	DATE: 10-28-03	DWG NO. C04B007								
DB-CV COPPER DOUBLE SIDE BREAK HORIZ. & VERT. MOUNTED "V" DISCONNECT SWITCH - 115kV-161kV; 1200A-2000A												