




STYLE NO.	kV NOM.	kV BIL	"A"	"B"	"C"	"D"	"E"	"F"	"G"	"H"	"J"	"K"	"L"	"M"	"N"	"P"	"Q"	"R"	"S"	"T"	WEIGHT	INSUL.
G01	7.2	75	57	55 3/4	16	15	30	53 3/4	17 3/4	6 3/4	34	21 1/8	31 3/8	35 3/4	6	-	-	-	-	4 3/8	595 LBS.	TR 222
G02	15	110	66	64 3/4	17 1/4	18	34 1/4	62 3/4	22	7 3/4	38 1/4	23 3/8	37 1/4	47	9	-	-	-	-	6 3/8	650 LBS.	TR 225
G03	23	150	66	64 3/4	17 1/4	18	34 1/4	62 3/4	26 1/2	7 3/4	42 3/4	26 1/8	44 3/8	53 1/2	14	50 1/2	51	46 5/8	53 3/4	6 3/8	775 LBS.	TR 227

TABLE 1	
4 1/8	2
4 7/8	4
5 1/2	6
6 1/4	8
6 7/8	10
7 5/8	12



NOTE:
 1) "T" DIM. EQUALS LENGTH AVAILABLE FOR AUXILIARY SWITCH MTG. SEE TABLE 1 FOR LENGTH REQ'D. BASED ON NO. OF CONTACTS. IF MORE LENGTH IS REQ'D. THE CABINET SIZE MUST BE INCREASED.



REV	CODE A	Cleveland/Price, Inc. 14000 Route 993 : Trafford, PA. 15085		
		DRAWN: JRS	CHECKED: PMK	DATE: 2-2-04
LCG-C 7.2-23KV, 3000 AMP 120 KA MOM. OUTLINE			DWG NO. COOB026	

REVISION