


SWITCH STYLE No.	RATINGS				POST INSUL. TR#	DIMENSIONS IN INCHES MILLIMETERS SHOWN IN ()							WEIGHT/POLE (INCL. INSUL.)		
	NOM kV	MAX kV	KV BIL	AMPS		MO M kA	"A"	"B"	"C"	"D"	"E"	"R"	"T"	LBS.	KG
							(16)	(133)	(1143)	(2184)	(940)	(489)	(921)	.25 (6)	792 [359]
C04B003G01	115	123	550	1200	61	286	58.22 (1479)	45 (1143)	86 (2184)	37 (940)	19.25 (489)	36.25 (921)	.25 (6)	792 [359]	[362]
C04B003G02				1600	70		58.85 (1495)						.5 (13)	838 [380]	
C04B003G03				2000	100		67.22 (1707)						.25 (6)	909 [412]	
C04B003G04	138	145	650	1200	61	288	67.22 (1707)	54 (1372)	86 (2184)	37 (940)	24.5 (622)	36.25 (921)	.25 (6)	914 [415]	[415]
C04B003G05				1600	70		67.85 (1723)						.5 (13)	955 [433]	
C04B003G06				2000	100		75.22 (1911)						.25 (6)	1065 [483]	
C04B003G07	161	170	750	1200	61	291	75.22 (1911)	62 (1575)	94 (2388)	41 (1041)	29 (737)	40.13 (1019)	.25 (6)	1075 [488]	[488]
C04B003G08				1600	70		75.85 (1927)						.5 (13)	1116 [507]	
C04B003G09				2000	100										

- NOTES:
1. C.C.W. SWING TO OPEN SHOWN. C.W SWING TO OPEN OPP. HAND.
 2. COPPER TERMINAL PADS.
 3. INSULATORS INVERTED FOR UNDERHUNG MOUNTING.
 4. CUSTOMER TO SUPPLY "X" & "Y" DIMENSIONS.
 5. ALL DIMENSIONS ARE IN INCHES.
 6. DIMENSIONS IN () ARE IN MILLIMETERS.
 7. WEIGHTS IN [] ARE IN KILOGRAMS.
 8. DIM. "E" CONFIRMED BY TEST RESULTS.

ENGINEERING REF.: C04B002

REVISION	A: TITLE WAS "600A". GH 07-02-1997.						
REV	B: JUS TO 5" MAX. KV. C: UPDATED WEIGHTS. BUS 8-17-2008.						
CODE	D: UPDATE WEIGHTS. UPGRADED TO 5" DIA. RWS 8-31-2008. E: UPDATED "R" DIMS. RC Feb. 4, 2012.						
A00	REV	-E	 Cleaveland/Price Inc. 14000 Route 993 : Trafford, PA 15085		SHEET 1 OF 1 SCALE PROPORTIONAL		
DRAWN DP CHECKED SF DATE 06/23/1997				DWG NO. C04B003			
DB-C COPPER DOUBLE SIDE BREAK DISCONNECT SWITCH OUTLINE - 115-161KV, 1200-2000A WITH 5" B.C. INSULATORS							